

---

**ADDENDUM NO. 3**

The following general questions have been received and the responses are as follows:

Q1. *Are the electronic files for the existing surface along the canal right of way (drawings C101 – C104) available to the contractor for the use of bidding and takeoff purposes?*

A1. No - The existing surface along the canal is not available at this time.

Q2. *Some informational drawings (R1802 and R1803) show cross sections of the existing canal. Do the cross sections include the roadway surfacing that exists today?*

A2. No – Road improvements including quarry spalls and CSBC were added in 2022. Also, please be aware that the as-built information shown in the reference drawings are from the as-builts and at NAGV 29 datum.

Q3. *What can we assume for the materials in the existing roadway surfacing section?*

A.3 Assume the following for the existing roadway - 12" Quarry Spalls, 6" CSBC.

KITTITAS RECLAMATION DISTRICT

Dated this 27th day  
of October, 2023

By:   
John Etulain

Title: Project Engineer